

	EPA	DOT
Governing Regulation	* 40 CFR Part 112, Subpart B	49 CFR 195.432
Governing Rules / Practice	* SPCC Rules	API 653
Definition of Jurisdiction	* In-service atmospheric low-pressure aboveground storage tank.	"Breakout tank" with product both received from and discharged to a DOT-regulated interstate pipeline
Inspection and Monitoring	* Frequent external visual inspections * Regularly scheduled integrity testing * Visual testing combined with another form of non-destructive shell testing *	Informal: every 2-3 weeks Formal, external: 5 yr minimum External ultrasonic: every 5-15 yrs Internal: every 10-20 years